

TEST REPORT

Customer Name	International Delhi Public School R.S. Pura.			
Customer Ref No:				
Sample Quantity:	2 litre	Sample Container Condition:	OK / Not Satisfactory	
Sample ID:	JSO SL 662	Date of Receipt:	24/07/2025	
Report No:	662	Report Date:	26/07/2025	
Sample Details:	International Delhi Public School R.S. Pura Jammu.	Source:	Borewell	
Test Start Date:	24/07/2025	Test End Date:	25/07/2025	
Sample Collected by	Mr. Ramesh Sharma			

Sr. No.	Parameter	BIS Permissible Limit	Unit	Test Results	Test Method
1.	pH	6.5-8.5	—	5.96	IS 3025 (Part 11)
2.	Colour	15	HU	05	IS 3025 (Part 4)
3.	TDS	2000	mg/l	115	IS 3025 (Part 16)
4.	Turbidity	5	NTU	0.88	IS 3025 (Part 10)
5.	Iron	1.0	mg/l	0.15	IS 3025 (Part 53)
6.	Chloride	1000	mg/l	5.99	IS 3025 (Part 32)
7.	Magnesium	100	mg/l	4.37	IS 3025 (Part 46)
8.	Sulphate	400	mg/l	4.87	IS 3025 (Part 24)
9.	Calcium	200	mg/l	24.84	IS 3025 (Part 40)
10.	Total Hardness	600	mg/l	82.0	IS 3025 (Part 21)
11.	Alkalinity	600	mg/l	65.0	IS 3025 (Part 23)

Note:

- The test report and result relate to the material's specimen/ sample (s) as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test report.
- WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/ legal liability arising out of any errors or omissions.
- The report has been presented in a simplified manner and the test conditions will be available on request.
- This laboratory does not provide the statement of conformity (Pass/ Fail), opinion and interpretation.
- Results apply to the sample as received.
- Humidity (40-60)% Temp. @ 20 ± 2,**

*ADL: Above Detectable Limits, *BDL: Below Detectable Limits.

Reviewed by:

Anil Sharma
 (Mr/Ms: Anil Sharma
 Designation: Chemist)

Rohit Sharma

Authorised Signatory

(Mr/Ms: Rohit Sharma,
 Designation: Chemist)

End of Report



STATE WATER TESTING LABORATORY, JAL BHAWAN, NARWAL, JAMMU

JAL SHAKTI (PHE) DEPARTMENT, UT OF J&K
DOC Ref: PHE/WQC/SLJ/QF-7.8-01

TEST REPORT

Customer Name:	International Delhi Public School, R.S.Pura		
Customer Ref No:	-		
Sample Quantity:	2 litre	Sample Container Condition:	OK / Not Satisfactory
Sample ID:	JSD/SL/662	Date of Receipt:	24/07/2025
Report No:	662	Report Date:	26/07/2025
Sample Details:	International Delhi Public School, R.S.Pura		
Test Start Date:	24/07/2025	Test End Date:	25/07/2025
Sample Collected by	Mr. Ramesh Sharma.		

Sr. No.	Parameter	Unit	Observation	Test Results
01	E-Coli	-	Present/Absent	Absent.

Note:

- The test report and result relate to the material's specimen/ sample (s) as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test report.
- WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/ legal liability arising out of any errors or omissions.
- The report has been presented in a simplified manner and the test conditions will be available on request.
- This laboratory does not provide the statement of conformity (Pass/ Fail), opinion and interpretation.
- Results apply to the sample as received.

Reviewed by:
 (Mr/Ms: Anil Mahajan)
 Designation: Chemist

Authorised Signatory
 (Mr/Ms: Sanjeev Thakur)
 Designation: AEE/Chemist